



National Construction Code (NCC) Requirements

Commercial

Class 2 - Class 9 buildings

J3.4 Windows and doors

- (a) A seal to restrict air infiltration must be fitted to each edge of a door, openable *window* or the like forming part of—
- (i) the envelope of a *conditioned space*; or
 - (ii) the external fabric of a habitable room or public area in *climate zones 4, 5, 6, 7 and 8*.
- (b) The requirements of (a) do not apply to—
- (i) a *window* complying with AS 2047; or
 - (ii) a fire door or smoke door; or
 - (iii) a roller shutter door, roller shutter grille or other security door or device installed only for out-of-hours security.
- (c) A seal required by (a)—
- (i) for the bottom edge of an external swing door, must be a draft protection device; and
 - (ii) for the other edges of an external door or the edges of an openable *window* or other such opening, may be a foam or rubber compression strip, fibrous seal or the like.
- (d) An entrance to a building, if leading to a *conditioned space* must have an airlock, self-closing door, revolving door or the like, other than—
- (i) where the *conditioned space* has a floor area of not more than 50 m²; or
 - (ii) where a café, restaurant, open front shop or the like has—
 - (A) a 3 m deep unconditioned zone between the main entrance, including an open front, and the *conditioned space*, and;
 - (B) at all other entrances to the café, restaurant, open front shop or the like, self-closing doors.

Residential

Class 1 and Class 10 buildings

3.12.3.3 External windows and doors

- (a) A seal to restrict air infiltration must be fitted to each edge of an external door, openable *window* and other such opening—
- (i) when serving a *conditioned space*; or
 - (ii) in *climate zones 4, 5, 6, 7 and 8*, when serving a habitable room.
- (b) A *window* complying with the maximum air infiltration rates specified in AS 2047 need not comply with (a).
- (c) A seal required by (a).
- (i) for the bottom edge of an external swing door, must be a draft protection device; and
 - (ii) for the other edges of an external swing door or the edges of an openable *window* or other such opening, may be a foam or rubber compressible strip, fibrous seal or the like.

Ember Attack - BAL Ratings

Where door sets are being specified in Bush Fire Prone areas, door seals, weather stripping and draught excluders are required to meet AS 3959 to comply with the NCC. The BAL rating is determined by the site location and the attributing factors for bushfire attack to which AS 3959 gives guidance. Attention needs to be paid to specifying to the correct BAL rating as determined by AS 3959. Refer to the selection table [page 29](#).



Related Building Codes

There are several standards, which refer to seal properties and testing for weather - energy:

AUS / NZ

Requirements are noted in the Australian National Construction Code (NCC) and New Zealand NZ BC Compliance Doc. H.

UK / EU

Requirements are noted in the British Building Regulations Approved Document L1 & L2.

USA

Requirements are noted in the Building Code and the Residential Code IBC 2000.

For further details, refer to Standards / Authorities on page 118.